



MILFORD WATER COMPANY

66 Dilla Street, Milford, MA 01757
Tele: 508-473-5110 Fax: 508-478-7997
Email: milfordwater@milfordwater.com

June 11, 2018

Zoning Board of Appeals
Town Hall
52 Main Street
Milford, MA 01757
c/o Gerald M. Moody

RE: Dilla Street wells available flows after upgrades.

Mr. Moody,

After having attended my second public hearing on the proposed 40B projects being brought before the Town I thought it would be good for me to try and clarify the volumes of water needed for the projects and the amount of available water that could be used by the residence of Milford once the upgrades to both the Godfrey Brook wellfield and the Dilla Street wellfield.

As I had stated during the hearing the developers of both the Robsham Village and the Stone Ridge 40B projects have agreed to work with the Company to invest in wellfield redevelopment and upgrades to provide the required demands for their respective projects. Also as stated we have now begun to look at the redevelopment of Dilla Street wellfield which currently has the ability to provide approx. 85 of its 470 gpm approved pumping volume. The advantage of working to improve Dilla Street wellfield is that the water is processed through the Dilla Street plant so there would be no need for additional treatment.

To compare the demands needed by the proposed projects and the amount of water that would be available once the Dilla Street wellfield redevelopment and upgrades have been completed I offer the following;

Project	Demand - daily	Dilla St – current daily	Available to customers - daily
Robsham Village	32,900 gals	122,400 gals	89,500 gals
Stone Ridge	29,800 gals	122,400 gals	92,600 gals
Birch Street	17,700 gals	122,400 gals	104,700 gals
Total	80,400 gals	122,400 gals	42,000 gals

Project	Demand - daily	Dilla St – daily, after upgrades	Available to customers - daily
Robsham Village	32,900 gals	675,000 gals	642,100 gals
Stone Ridge	29,800 gals	675,000 gals	645,200 gals
Birch Street	17,700 gals	675,000 gals	657,300 gals
Total	80,400 gals	675,000 gals	594,600 gals

I hope that this may help to clarify to the Board that the improvements to the Dilla Street wellfield would provide to our existing customers approx. 595,000 gallons per day of additional water that is currently unavailable at this time.

The Company is fully committed in working as quickly as possible to get the Godfrey Brook wellfield back to its original capacity and by working with the 40B project developers on the Dilla Street wellfield as a possible added benefit to some of our capacity issues.

Respectfully Submitted,
David L. Condrey
Manager, Milford Water Company