

January 26, 2021

Mr. David R. Consigli Chairman Town of Milford - Zoning Board of Appeals (ZBA) 52 Main Street Milford, MA

#### Re: The Residences at Stone Ridge - Phase II

Response to Sewer Department Comments

SMMA No. 19162

Dear Mr. Consigli:

On behalf of our client, The Gutierrez Company (TGC), SMMA has prepared the response below to the Sewer Review letters prepared by Tata & Howard (T&H), dated September 28, 2020 and November 17, 2020. Attached with this letter are the requested pump system details including pump station calculations, pump technical data, and two exhibits showing the proposed 19,000-gallon emergency storage tank.

Per the suggestions in Tata & Howard's September 28, 2020 Sewer Review letter, we propose to eliminate the Upper Deer Street Pump Station and instead provide additional emergency storage at the Lower Deer Street Pump Station. The 8 ft and 10 ft diameter pump stations will remain (bottom of tanks = 284.13, pump range = 286.0 – 287.5). We propose a 19,000 gallon emergency storage tank beneath Deer Street connected to the original 8 ft diameter pump station with two equalization pipes. The equalization pipes and the proposed emergency storage tank bottom will be at upper pump range elevation = 287.5. The emergency storage tank will be located 10 ft from the water main and hydrant service. It will require realigning a short segment of the existing 6" force main around the proposed emergency tank. In the event the tank requires maintenance or cleaning, the tank will have two 24" diameter manhole access covers and there will be direct access from Deer Street. This storage tank will provide sufficient capacity for all of the remaining developable land.

We look forward to discussing this information with the Town of Milford Board of Sewer Commissioners and their consultant, Tata & Howard. If you have any questions, please feel free to contact me at 617-520-9210 or <u>wpark@smma.com</u>.

Very truly yours,

SMMA

PL W.M

William Park, PE Senior Associate | Civil Engineer

cc: Israel Lopez - The Gutierrez Company, Peter Glick - SMMA, (MF)

enclosures: Pump Station Design Calculations and Exhibits

1000 Massachusetts Avenue Cambridge, MA 02138 617.547.5400

www.smma.com



## Stone Ridge SMMA #19162 Date: 12/04/2020, Rev. 01/25/2021 Pump Station Design - Currently Proposed -w/Modified & New Pump Station Configuration

						Hours	Adj. Max.	Peak	Peak Flow	Adj. Peak
Use	Quantity	Unit	Rate		GPD	Ор.	Flow (GPM)	Factor	(GPD)	Flow (GPM)
Restaurant	62.095	og ft	FO	per 1000	0 164	10	4.00	2.0	0.462	10
Depot	63,085	sq. ft.	50	sq. ft.	3,154	12	4.38	3.0	9,463	13
Residences -		bedroom		per						
Phase I	383	S	110	bedroom	42,130	18	39.01	4.0	168,520	156
Residences -				per						
Phase II	460	bedrooms	110	bedroom	50,600	18	46.85	4.0	202,400	187
Swimming				gpd/						
Pool	104	persons	10	person	1,040	18	0.96	4.0	4,160	4
1/1	1,450	li. ft.	200	gpd/idm	439	24	0.30	4.0	1,756	1
Future										
Development	C	onceptual D	Design Flo	wc	21,120	12	29.33	3.0	63,360	88
Total					118,483		121		449,659	450

B. High Point in Force Main (ft) =304.00Pump Off Elevation (ft) =286.00Elevation Head (ft) =18.00

C. Force Main Velocity Check:	Dia.(in) =	6
	Length (ft) =	2347
	Assumed Qpump (gpm) =	475
	Material =	PVC
	* Velocity (ft/s) =	5.39
	Hazen-Williams "C" value =	140

\* (3.00 ft/s < velocity <7.00 ft/s)



D. Minor Losses in Fittings "K" Value (Included in Total Equivalent Length)

Apparatus	Quantity	"K" Value(	Quantity * K
Check Valve	1	1.80	1.80
Enlargement	0	0.10	0.00
90° Bend	4	0.54	2.16
6" Gate Valve	1	0.14	0.14
Tee Branch	0	1.08	0
Tee Through	0	0.36	0.00
45° Bend	8	0.29	2.32
22.5° Bend	0	0.24	0.00
Pipe Exit	1	1.00	1.00
	Т	otal "K" =	7.42



## **II. SYSTEM HEAD COMUTATIONS**

Given:	Forcemain Diameter (in) =	6
	Length of Forcemain (ft) =	2347
	Hazen-Williams "C" Value =	140
	Minor Loss "K" Value =	7.42
	High Point Elevation (ft) =	304.00
	Pump Off Elevation (ft) =	286.00

 $\begin{array}{l} \mbox{Minor Headloss (Hm) = K^{*}((V^{2})/(2^{*}G)) \\ \mbox{Friction Headloss (Hf) = } 2.083 * (L/1000)^{1.85} * (gpm^{1.85} / dia^{4.8655}) \\ \mbox{Static Headloss (Hstat) = Discharge Elevation - Pump Off Elevation} \\ \mbox{Total Dynamic Head (TDH) = Hm + Hf + Hstat} \end{array}$ 

Q (gmp)	V (fps)	Hm (ft)	Hf (ft)	Hstat (ft)	TDH	
	0.00	0.00	, ,	18.00		-
0			0.00		18.00	
25	0.28	0.01	0.17	18.00	18.17	
50	0.57	0.04	0.60	18.00	18.63	
75	0.85	0.08	1.26	18.00	19.35	
100	1.14	0.15	2.15	18.00	20.30	
125	1.42	0.23	3.25	18.00	21.48	
150	1.70	0.33	4.56	18.00	22.89	
175	1.99	0.45	6.06	18.00	24.51	
200	2.27	0.59	7.76	18.00	26.35	
225	2.55	0.75	9.65	18.00	28.40	
250	2.84	0.93	11.72	18.00	30.65	
275	3.12	1.12	13.98	18.00	33.10	
300	3.41	1.34	16.42	18.00	35.76	
325	3.69	1.57	19.04	18.00	38.61	
350	3.97	1.82	21.84	18.00	41.66	
375	4.26	2.09	24.82	18.00	44.90	
400	4.54	2.38	27.96	18.00	48.34	
425	4.83	2.68	31.28	18.00	51.96	
450	5.11	3.01	34.77	18.00	55.78	
475	5.39	3.35	38.43	18.00	59.78	Qpu
500	5.68	3.71	42.25	18.00	63.97	•
525	5.96	4.09	46.25	18.00	68.34	
550	6.24	4.49	50.40	18.00	72.89	
575	6.53	4.91	54.72	18.00	77.63	
600	6.81	5.35	59.20	18.00	82.55	
			-			



## **III. WETWELL DESIGN**

A. Volume of Wetwell

V = t * q /	4	t = minimum cycle time (min) q = peak flow (gpm) V = volume (gal)
t =	15	
q =	29	
V =	109	

B. Wetwell & Pump Elevations:

298.00	Top of Slab
290.00	Invert In
288.00	Lag Pump On & High Water Alarm
287.50	Lead Pump On
286.00	Pumps Off and Alternate
285.80	Low Water Alarm
284.80	Bottom Inside of Chamber

C. Effective Capacity of Wetwell Chamber:

	Wetwell A	Wetwell B
Inside Dia. (ft) =	8.00	10.00
X - Area (sf) =	50.3	78.5
Effective Capacity (gal) =	564	881

Total Capacity Wetwell A + Wetwell B = 1,445

# D. Emergency Storage Capacity:

Wetwells A & B Above "Pump On" Elevation to Underside of Slab =	9,471	Gal.
Emergency Storage Tank (ID = 36'-5" L x 10'-0" W x 8'-0" H) Above "HW	A"	
Elevation (288.0) to Underside of Tank Slab (296.0) $=$	20,645	Gal.
Tota	al = 30,116	Gal.



## **IV. WETWELL DETENTION TIMES**

A. Time to Empty Wetwell (pump run start to stop)

T1 = Effective Capacity / ( Qpump - Qin)

Effective Capacity (gal) =	1445
Pumping Rate (gpm) =	475
Max. Daily Flow (gpd) =	118,483
Peak Flow (gpm) =	450
Max. Daily Flow (gpm) =	121

1. No Inflow:	T1(min) =	3.04
2. Maximum Daily Inflow:	T1(min) =	4.08
3. Peak Inflow:	T1(min) =	57.03
4. 1/2 Of Pump Rate:	T1(min) =	6.09

## B. Time to Fill Wetwell (pump off)

T2 = Effective Capacity - Qin

1. No Inflow:	T2(min) =	N/A
2. Maximum Daily Inflow:	T2(min) =	11.96
3. Peak Inflow:	T2(min) =	3.21
4. 1/2 Of Pump Rate:	T2(min) =	6.09

## C. Cycle Time (pump start to start)

Tt = T1 + T2

1. No Inflow:	Tt(min) =	N/A
2. Maximum Daily Inflow:	Tt(min) =	16.04
3. Peak Inflow:	Tt(min) =	60.24
4. 1/2 Of Pump Rate:	Tt(min) =	12.17

Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Possible to be upgraded with Guide-pin® for even better clogging resistance. Modular based design with high adaptation grade.



# Technical specification



	water, pure ,	55.2 1,0	2.42 10/1	,1.005	12 5 10 / 5
[ft] Head					
104					
100					
96					
92					
88	、				
84	$\rightarrow$				
80-	$\rightarrow$				
76-	+ + +				
72					
68	+				
64		$\backslash$			
60					
56					
52		68.8%	$\setminus$		
48					
44			$\sim$		
40			```		
36				$\mathbf{h}$	
32					
28				`	
24					
20					
16					465 239mm
12					
8					
4					
0	200 400	60		800	1000 [US g.p.m.]
U	200 400	00	<i>.</i>	00	Curve: ISO 9906

#### Configuration

Motor number N3153.830 21-15-4AS-W IE3 14hp Impeller diameter 239 mm Installation type P - Semi permanent, Wet

Discharge diameter 4 inch

## **Pump information**

Impeller diameter 239 mm

Discharge diameter 4 inch

Inlet diameter 150 mm

Maximum operating speed 1800 rpm

Number of blades 2

Max. fluid temperature

40 °C

Project Created by	Ian Belczyk	Last update	12/8/2020
Block Created on	12/8/2020		

Materials

Hard-Iron ™

#### Curves according to: Water, pure ,39.2 °F,62.42 lb/ft<sup>3</sup>,1.6891E-5 ft<sup>2</sup>/s

# Technical specification


## Motor - General

Motor number	Phases	Rated speed	Rated power
N3153.830 21-15-4AS-W IE3 14hp	3~	1800 rpm	14 hp
ATEX approved	Number of poles	Rated current	Stator variant
FM	4	14 A	15
Frequency	Rated voltage	Insulation class	Type of Duty
60 Hz	460 V	Н	S1
Version code			
830			
Motor - Technical			
Power factor - 1/1 Load	Motor efficiency - 1/1 Load	Total moment of inertia	Starts per hour max.
100001100001 1/12000	motor emelency 1/1 Louis	Total moment of mertia	
0.98	92.8 %	1.96 lb ft <sup>2</sup>	30
0.98 Power factor - 3/4 Load	92.8 % Motor efficiency - 3/4 Load	1.96 lb ft <sup>2</sup> Starting current, direct starting	30
			30
Power factor - 3/4 Load	Motor efficiency - 3/4 Load	Starting current, direct starting	30

FLYGT

a **xylem** brand

Project	Created by	Ian Belczyk	Last update	12/8/2020
Block	Created on	12/8/2020		







Curves according to: Water, pure ,39.2  $^\circ\text{F}$  ,62.42 lb/ft³,1.6891E-5 ft²/s [ft] Head 1 104-100-96-92-88-84-80-76-72-68-64-61.4 ft 60-56-68.8% 52-48-44-40-36-32-28-24-20-16 465 239mm 12 8 4-485.8 US g.p.m. 0-100 200 300 400 500 600 700 800 900 1000 0 1100 [US g.p.m.] **Operating characteristics** Specific Energy Pumps / Systems Flow Head Shaft power Flow Head Shaft power Hydr.eff. NPSHre 1 486 US g.p.m. 61.4 ft 11.1 hp 486 US g.p.m. 61.4 ft 11.1 hp 68.1 % 307 kWh/US M( 13.6 ft 12/8/2020 Project Created by Ian Belczyk Last update 12/8/2020 Block Created on


VFD Curve




Curves according to:  $\ \$  Water, pure , 39.2 °F, 62.42 lb/ft³, 1.6891E-5 ft²/s [ft] Head 105 100 95 90-85 80-75 70-65 60 68.8% 55-50-45 68.8% 40-35 68.8% 30-25 20-1200 rpm 465 239mm 15 10 5 0 [%] Pump Efficiency 60 Overall Efficiency 50 40 1288 F871358 F871560 F871650 F87465 239mm 30-20-10 [hp] Pow er input P1 465 239mm (P1) 465 239mm (P2) 12 Shaft pow er P2 10-1630 FBM 8--1200 FBM 1388 FBA 6 4 2 0 NPSHR-values ~465 239mm [ft]-NPSHR = 32.809 ft 30-500 rpm 25 359 rpm 20pm 15-10-1100 [US g.p.m.] Curve: ISO 9906 100 200 300 400 500 600 700 800 0 900 1000 12/8/2020 Project Created by Ian Belczyk Last update 12/8/2020 Block Created on



VFD Analysis










# FP/NP-3153

- NOTES:
- 1. CONFIGURATION AND DIMS. SHOWN ARE SUGGESTED REQUIREMENTS ONLY. ALL DETAILS, INCLUDING SIZING OF PIT, TYPE, LOCATION AND ARRANGEMENT OF VALVES AND PIPING, ETC. ARE TO BE SPECIFIED BY THE CONSULTING ENGINEER AND ARE SUBJECT TO THEIR APPROVAL.
- 2. REFERENCE GENERIC DUPLEX LIFT STATION LAYOUT FOR ELEVATION VIEW.
- 3. LOCATE ANCHOR BOLTS USING INSIDE EDGE OF CLEAR OPENING AND PUMP CENTERLINE AS REFERENCE POINT. BOLT LOCATIONS MUST BE HELD TO MAINTAIN EXACT POSITION OF PUMP TO CLEAR OPENING.
- 4. ITT FLYGT MIX-FLUSH VALVE.





Specifications subject to change without notice



	DATE: 0	01/26/2021	STONE RIDGE	SMMA
	ISSUE:			_
	SCALE:			
SECTION THROUGH LOWER DEER	REF:		JEEK SIKEEI AILFORD. MA	SYMMES MAINI & MCKEE ASSOCIATES
STREET EXISTING PUMP STATION	DR BY:	PSG		1000 Massachusetts Avenue Cambridge, Massachusetts 02138
PROPOSED WET WELL, AND EMERGENCY STORAGE TANK	CK BY:	CHK	JOB NO.: 19162.00	P:617.547.5400 F:617.648.4920

