



May 27, 2021

Mr. Rudolph V. Lioce III, Chairman
Board of Sewer Commissioners
Post Office Box 644
Milford, MA 01757

Subject: The Residences at Stone Ridge – Phase II
Plan Review
Milford, Massachusetts
T&H No. 1112

Dear Mr. Lioce:

Tata & Howard (T&H) has reviewed the Plans from Symmes Maini & McKee Associates (SMMA) dated May 11, 2021. The plans have relocated the storage tanks out of the right-of-way and appear to have addressed previous review comments from previous submissions.

We recommend the providing conditional approval of the current submission contingent on the applicant providing isolation valves as need on the equalization pipes to allow isolation of the storage tanks and wet well to accommodate maintenance or repairs.

We appreciate the opportunity to review the plans for the Board. Please call if you have any questions or concerns.

Sincerely,
TATA & HOWARD, INC.

James V Hoyt, P.E.
Project Manager

cc: Mr. John Mainini – Town of Milford
enclosures