



July 9, 2018

Mr. Richard J. Cenedella, Chairman  
Board of Sewer Commissioners  
Post Office Box 644  
Milford, MA 01757

Subject: The Residences at Stone Ridge  
Sewer Review  
Milford, Massachusetts  
T&H No. 1112

Dear Mr. Cenedella:

As agreed upon at the June 5, 2018 meeting, The Gutierrez Company shall install a 10-foot inside diameter wet well adjacent to the proposed pump station at the Residences at Stone Ridge. A 7.5 horsepower, 350 gallon per minute pump shall be installed in the additional wet well.

We appreciate the opportunity to review this application for the Board. Please call if you have any questions.

Sincerely,  
TATA & HOWARD, INC.

Steven J. Landry, P.E.  
Vice President

cc: Mr. John Mainini – Town of Milford